

Zertifikat Certificate



Zertifikat Nr. Certificate No.
R 60100617

Blatt Page
0001

| Ihr Zeichen Client Reference | Unser Zeichen Our Reference | Ausstellungsdatum Date of Issue | (day/mo/yr) |
|------------------------------|-----------------------------|---------------------------------|-------------|
| | 0001-- 27122089 001 | 19.03.2015 | |

Genehmigungsinhaber License Holder

ÖREN KABLO ELEKTRİK VE ELEKTRONİK
SİSTEMLERİ SANAYİ TİCARET LTD.ŞTİ.
ORTAKÖY SAN.BÖLGESİ P.K.TR-34617
SELİMPAŞA-SİLİVRİ-İSTANBUL
Türkiye

Fertigungsstätte Manufacturing Plant

ÖREN KABLO ELEKTRİK VE ELEKTRONİK
SİSTEMLERİ SANAYİ TİCARET LTD.ŞTİ.
ORTAKÖY SAN.BÖLGESİ P.K.TR-34617
SELİMPAŞA-SİLİVRİ-İSTANBUL
Türkiye

Prüfzeichen Test Mark



Type Approved
Safety
Regular Production
Surveillance

www.tuv.com
ID 2000000000

Gepprüft nach Tested acc. to

DIN VDE 0815:1985+A1
DIN VDE 0812/11.88

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Cable


Code Designation : LIHCH FE 180 PH 180 5
Trade Mark : ÖREN KABLO
Number of Cores : 2-4
Nominal cross-sectional areas: 0,50mm², 0,75mm², 1,00mm²
1,5mm², 2,5mm²
Conductor : Flexible plain copper conductor (Class5)
according to IEC 60228
Resistance to fire (acc.to EN 50200): PH 180
Circuit integrity (acc to IEC 60331-23): FE 180

Refer to test report for constructional parameters
and test results.

Fire Performance-Category C acc.to EN 60332-3-24
Flame Propagation acc.to EN 60332-1-2
Smoke Density acc.to EN 61034-2
Halogen Free characteristics acc.to EN 50267-2-2 and
EN 50267-2-1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg
Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety



Sahure Oralalp

